



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20107279482

Type II CQC Certification

## NAME AND ADDRESS OF THE APPLICANT

SOCOMEK S.A

1, Rue De Westhouse 67230 Benfeld Cedex France

## NAME AND ADDRESS OF THE MANUFACTURER

SOCOMEK S.A

1, Rue De Westhouse 67230 Benfeld Cedex France

## NAME AND ADDRESS OF THE FACTORY

SOCOMEK S.A (V005810)

1, Rue de Westhouse 67230 BENFELD CEDEX FRANCE

## PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-switch-disconnector

FUSERBLOC 315A,FUSERBLOC 400A; (Uimp):8kV; (Ui):800V; (Ith): 315A(FUSERBLOC 315A),400A(FUSERBLOC 400A); (Ue)/(Ie): AC-22B:AC690V/400A(FUSERBLOC 400A); AC-23A:AC690V/315A(FUSERBLOC 315A); (Iq):50kA; AC-22B,AC-23A; 2P,3P,4P,3P+Additional neutral pole; 50/60Hz

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020 .

Valid from: Dec.29,2020

Valid until: Dec.29,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: \_\_\_\_\_

Lu Mei



# CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0412252