

CERTIFICATE OF COMPLIANCE

Certificate Number 20120321-E346418
Report Reference E346418-20120124
Issue Date 2012-MARCH-21
Issued to: **Socomec S A**
1 RTE DE WESTHOUSE
BOITE POSTALE 10
BENFELD CEDEX , 67235, FR

**This is to certify that
representative samples of**

SWITCHES, OPEN TYPE FOR USE IN PHOTOVOLTAIC SYSTEMS
Enclosed switches, manual, Cat. Nos. 27PV3060, 27PV4060, 27PV6060, 27PV8060

RATINGS:
OPEN TYPE SWITCHES, MANUAL FOR USE IN PHOTOVOLTAIC SYSTEMS

Model	Current Rating, A General Use	Voltage, DC	Number of Poles in series	Short Circuit Rating, kA
27PV3060 27PV4060 27PV6060 27PV8060	600	600	3	10 @
27PV4060 27PV8060	600	1000	4	10 @

Ambient range -20 to +50 °C

@ When protected with any fuses (50ms test without protection)

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety:

UL 98 - ENCLOSED AND DEAD-FRONT SWITCHES - Edition 13,
UL 98B - ENCLOSED AND DEAD-FRONT SWITCHES FOR USE IN
PHOTOVOLTAIC SYSTEMS - Edition 1

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

