



Certificate of Compliance

Certificate: 2278405

Master Contract: 189705 (112964)

Project: 70107195

Date Issued: 2017-11-13

Issued to: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, Bas-Rhin 67235
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Patrick Quinty*
Patrick Quinty

PRODUCTS

CLASS - C465102 - SWITCHES-Dead-front (Open Type)

Part A

Open Type Switches, Manual, Series Fuserbloc J200A, Catalogue number: 38512020, 38513020, 38516020, 38612020, 38613020, 38616020, 38673020, 38676020.

Rating: General use: 200A max at 600Vac max.; 150HP max at 600Vac max. ; 200A at 250Vdc max.; 40Hp max at 250Vdc. 200kA at 600Vac and 100kA at 250V dc, 3/0AWG copper wire only.

Note: For use in a certified enclosure minimum size 24 by 20 by 8 in.

Part B

Terminal shroud Cat. Nos. 38982020, 38983020, 38984020.

Note:

- 1 Cat. Nos. 38982020 is for use with 2 pole switches, Cat. Nos. 38512020 & 38612020.
2. Cat Nos. 38983020 is for use with 3 pole switches Cat. Nos. 38513020 and 38613020 & 38673020.
3. Cat. Nos. 38984020 is for use with 4 pole switches Cat. Nos. 38516020 and 38616020 & 38676020.



Certificate: 2278405
Project: 70107195

Master Contract: 189705
Date Issued: 2017-11-13

Part C

Adaptation kits for flange handle, Cat. No. 39299992, 39299993 & 39299994 to be used with Rockwell handles Cat. No. 1494F-P1, 1494F-M1 and 1494F-S1 or fused switches series Fuserbloc J200A, cat. No.38613020.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 4-16 - Enclosed and Dead-Front Switches



Supplement to Certificate of Compliance

Certificate: 2278405

Master Contract: 189705 (112964)

***The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.***

Product Certification History

Project	Date	Description
70107195	2017-11-13	Update report as per Notice 17 and 21 (CSA C22.2 No.4-16).
2753091	2014-08-19	Addition of Adaptation kit for flange handle, Cat. No. 39299992, 39299993 & 39299994.
2719458	2014-04-24	Modification to the came dimensions.
2676044	2014-01-13	Modification of short-circuit rating of 250Vdc at 100kA.
2529483	2012-07-12	Addition of optional auxiliary holder, operating peg, handle cat no. 194R-HM4—N2-L and auxiliary contact cat nos 800x10, 800x01 by Rockwell into cat no. Fuserbloc J200.
2460091	2011-10-19	Addition of alternate plastic A3K by BASF.
2278405	2010-06-11	New certification Open type Switches, Series Fuserbloc J200A with terminal Shroud cat no. 38982020, 38983020, 38984020, as per CAN/CSA C22.2 No.4-04.