



Certificate of Compliance

Certificate: 2404139

Master Contract: 189705 (112964_0_000)

Project: 70107198

Date Issued: 2017-09-27

Issued to: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, 67235
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Patrick Quinty*
Patrick Quinty

PRODUCTS

CLASS - C465102 - SWITCHES-Dead-front (Open Type)

Part A

Open Type Switches, Manual, Fuserbloc J 400A, Cat. Nos. 38512038, 38513038, 38516038.

Rating: 350HP max at 600Vac, 3 phases; 50HP max at 250Vdc; General use: 400A max at 600Vac/250Vdc.
Short-circuit rating: 200kA at 600Vac.

Part B

Auxiliary Devices Cat. Nos:3999 U241 – (1 device), 3999 U242 – (2 devices)

Part C

Component T fuse conversion kit Cat. Nos. 37297040, 37298040, 37299040.

Part D

Component - Handles Cat. Nos. 36297910



Certificate: 2404139
Project: 70107198

Master Contract: 189705
Date Issued: 2017-09-27

Part E

Terminal shroud Cat. Nos. 38982040, 38983040, 38986040.

Notes :

1. Cat. No. 37297040 for use only with open type switches, Cat. Nos. 38512038.
2. Cat. No. 37298040 for use only with open type switches, Cat. Nos. 38513038.
3. Cat. No. 37299040 for use only with open type switches, Cat. Nos. 38516038.
4. Cat. No. 38982040 for use only with open type switches, Cat. Nos. 38512038.
5. Cat. No. 38983040 for use only with open type switches, Cat. Nos. 38513038.
6. Cat. No. 38986040 for use only with open type switches, Cat. Nos. 38516038.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 4-16 - Enclosed Switches



Supplement to Certificate of Compliance

Certificate: 2404139

Master Contract: 189705 (112964_0_000)

***The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.***

Product Certification History

Project	Date	Description
70107198	2017-09-27	Update report as per Notice 17 and 21 (CSA Standard CSA C22.2 No.4-16).
2529484	2012-07-12	Addition of optional auxiliary holder, operating peg, handle cat no. 194R-HM4—N2-L and auxiliary contact cat nos 800x10, 800x01 by Rockwell into cat no. Fuserbloc J400.
2404139	2011-08-31	New Certification – Open type Switches, manual, Fuserbloc J 400A.