



Ref. Certif. No.

CN55223

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOME S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOME S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCIETE TIMELEC SARL

ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN
1135 NAASSEN GOUVERNORAT DE BEN AROUS, Tunisia☒ Additional information on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 800V;Ith: 100A;Ue: AC690V;Ie: 100A;Utilization category:
AC-23A;Number of poles:2P,3P,4P;Iq: 50kA;Rated frequency :50/60Hz

Trademark / Brand (if any)

SOCOME

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC 100A;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099779

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.09,2021

Signature:

谢肇煦

Xie ZhaoXu



CB 0065328

Name of the factory	Address of the factory
1.SOCOMEK S.A.S	1, Rue De Westhouse 67230 Benfeld Cedex France

Additional information (if necessary)

Date: Nov.09,2021

Signature:


Xie ZhaoXu