

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOME S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOME S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOME S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

☒ Additional information on page 2

Ratings and principal characteristics

Uimp:8kV; Ui:800V; Ith:160A; Ue:AC415V,AC690V;
Ie:160A;AC-22B(AC690V),AC-23A(AC415V,AC690V); Iq:50kA; 2P,3P,4P,3P+Additional
neutral pole(3 protected poles with an uninterrupted neutral pole); 50/60Hz

Trademark / Brand (if any)

SOCOME

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC 160A

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-099769

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.09,2021

Signature:



Xie ZhaoXu



IEC

IECEE



TM

Ref. Certif. No.

CN55102

Name of the factory	Address of the factory
1.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Nov.09,2021

Signature:

谢肇煦

Xie ZhaoXu