

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOME C S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOME C S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOME C S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

☒ Additional information on page 2

Ratings and principal characteristics

Uimp: 8kV; Ui: 800V; Ith: 200A(FUSERBLOC200A); 250A(FUSERBLOC250A); Ue: AC690V; Ic: AC-22A: 200A(FUSERBLOC 200A); AC-23A: 160A(FUSERBLOC 200A); 250A(FUSERBLOC 250A) Utilization category: AC-22A, AC-23A Number of poles: 2P, 3P, 4P, 3P+Additional neutral pole (3 protected poles with an uninterrupted neutral pole); Iq: 50kA; Rated frequency: 50/60Hz

Trademark / Brand (if any)

SOCOME C

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC 200A, FUSERBLOC 250A;

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020; IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-099778

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.09,2021

Signature:


Xie ZhaoXu

CB 0065327

Name of the factory	Address of the factory
1.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Nov.09,2021

Signature:


Xie ZhaoXu