



Ref. Certif. No.

CN49970

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

DISCONNECTOR

Name and address of the applicant

SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Uimp: 12kV;Ui: 1000V;Ith: 2000A(SIRCO 2000A), 2500A(SIRCO 2500A),
3200A(SIRCO 3200A);Ue:AC415V;Ie: 2000A(SIRCO 2000A), 2500A(SIRCO
2500A), 3200A(SIRCO 3200A);Utilization category: AC-20B;Icw:
50kA/1s;Number of poles:6P,8P;Rated frequency:50/60Hz

Trademark (if any)

SOCOMEC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO 2000A,SIRCO 2500A,SIRCO 3200A;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-1:2007 (5th Edition) + AMD1:2010 + AMD2:2014;IEC
60947-3:2008(3rd Edition) + AMD 1:2012 + AMD 2:2015As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2020CQC-090942

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Apr.20,2020

Signature:

Lu Mei

CB 0056639