



Ref. Certif. No.

CN55379

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMEK S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMEK S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCIETE TIMELEC SARL

ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA
NAASSEN 1135 NAASSEN GOUVERNORAT DE BEN AROUS,
Tunisia

☒ Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

SOCOMEK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO 315A, SIRCO 400A, SIRCO 500A, SIRCO 630A, SIRCO CD
800A

Additional information (if necessary may also be
reported on page 2)

A sample of the product was tested and found
to be in conformity with

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-099884

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>



Date: Dec.21,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0066105

SIRCO 315A, SIRCO 400A, SIRCO 500A, SIRCO 630A, SIRCO CD 800A

Uimp: 12kV;

Ui: 1000V;

Ith: 315A(SIRCO 315A), 400A(SIRCO 400A), 500A(SIRCO 500A),
630A(SIRCO 630A), 800A(SIRCO CD 800A);

Ue: AC415V;

Ie: 315A(SIRCO 315A), 400A(SIRCO 400A), 500A(SIRCO 500A),
630A(SIRCO 630A), 800A(SIRCO CD 800A);

Icw: 13kA/1s(SIRCO 315A, SIRCO 400A, SIRCO 500A, SIRCO 630A), 16kA/1s(SIRCO CD
800A);

Icm(Peak): 26kA(SIRCO 315A, SIRCO 400A, SIRCO 500A, SIRCO 630A), 32kA(SIRCO CD
800A);

Iq: 100kA(SIRCO 315A, SIRCO 400A, SIRCO 500A), 70kA(SIRCO 630A);

Utilization category: AC-22A(SIRCO 630A), AC-22B(SIRCO CD 800A), AC-23A(SIRCO 315A,
SIRCO 400A, SIRCO 500A);

Number of poles: 3P, 4P;

Rated frequency: 50/60Hz

Page 1 of 1

Additional information (if necessary)

Date: Dec.21,2021

Signature:

谢肇煦

Xie ZhaoXu

IEC

IECEE

®

TM

Ref. Certif. No.

CN55379

Name of the factory	Address of the factory
1.SOCOMEK S.A.S	1, Rue De Westhouse 67230 Benfeld Cedex France

Additional information (if necessary)

Date: Dec.21,2021

Signature:

谢肇煦

Xie ZhaoXu