



Certificate of Compliance

Certificate: 2022442

Master Contract: 189705 (112964)

Project: 70107190

Date Issued: 2017-11-13

Issued to: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, Bas-Rhin 67235
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Patrick Quinty*
Patrick Quinty

PRODUCTS

CLASS - C465102 - SWITCHES-Dead-front (Open Type)

Part A

Open type double throw manual switches with off position, SIRCOVER 600, general purpose: 600A at 600Vac, 3 phases, 50/60Hz; 600A at 480Vac. 50/60 Hz, 3 phases; 600A at 250Vdc. Short circuit: 200kA at 600Vac, 100kA at 250Vdc and 20kA, 250Vdc protected with RK1 fuse at 600A. Catalogue number: 41503060 for 3 poles; 41504060 for 4 poles.

Part B

Open type double throw manual switches with off position, SIRCOVER 800, general purpose: 800A at 600Vac, 3 phases, 50/60Hz; 800A at 250Vdc. Short circuit: 100kA at 600Vac and 100kA at 250V dc. Catalogue number: 41503080 for 3 poles; 41504080 for 4 poles.

Open type double throw manual switches with off position, SIRCOVER 1200, general purpose: 1200A at 600Vac, 3 phases, 50/60Hz; 1200A at 250Vdc. Short circuit: 100kA at 600Vac and 100kA at 250V dc. Catalogue number: 41503120 for 3 poles; 41504120 for 4 poles.



Certificate: 2022442
Project: 70107190

Master Contract: 189705
Date Issued: 2017-11-13

Part C

Accessories Bridging bars Catalogue number 41593063, 41594063 are intended to be used on open type double throw manual switches SIRCOVER 600.

Accessories Bridging bars Catalogue number 41593080, 41594080 are intended to be used on open type double throw manual switches SIRCOVER 800 or SIRCOVER 1200.

Accessories Terminal screens Catalogue number 16093063, 16094063 are intended to be used on open type double throw manual switches SIRCOVER 600.

Accessories Terminal screens Cat. Nos. 16093080, 16094080 are intended to be used on open type double throw manual switches SIRCOVER 800 or SIRCOVER 1200.

Accessories Handle Catalogue number 41997012 is intended to be used on open type double throw manual switches SIRCOVER 600, 800 and 1200.

Accessories Handle Catalogue number 41997062 is a direct handle. Accessories Handle Catalogue number 41997149 is an external handle. These handles are intended to be used on open type double throw manual switches SIRCOVER 600, 800 and 1200.

Accessories shaft type V Cat. Nos. 41993018, 41993019. These shafts are intended to be used on open type double throw manual switches SIRCOVER 600, 800 and 1200.

Note:

- 1) For use in enclosure minimum size 48 inches by 36 inches by 20 inches for SIRCOVER 600
- 2) For use in enclosure minimum size 60 inches by 36 inches by 20 inches for SIRCOVER 800A and 1200A.
- 3) These devices are certified as components for use in equipment where the suitability of the combination is determined by CSA International.

APPLICABLE REQUIREMENTS

CSA C22.2 No.4-16 - Enclosed and Dead-Front Switches



Supplement to Certificate of Compliance

Certificate: 2022442

Master Contract: 189705 (112964)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70107190	2017-11-13	Update report as per Notice 17 and 21 (CSA C22.2 No.4-16).
2676042	2014-01-21	Modification of short-circuit rating of 250Vdc at 100kA.
2479891	2011-12-22	Addition of SIRCOVER 600 rating 600A/600Vac, 600A/250Vdc and 20kA/250Vac.
2022442	2008-07-10	New certification: open type double throw manual switches with off position: SIRCOVER 600, 800, 1200.