



# 中国国家强制性产品认证证书

证书编号: 2024010306649413

认证委托人名称及地址

法国溯高美电气公司

1, Rue De Westhouse 67230 Benfeld Cedex France

生产者名称及地址

法国溯高美电气公司

1, Rue De Westhouse 67230 Benfeld Cedex France

生产企业名称及地址

BROYCE CONTROL LTD

Pool Street. Wolverhampton, West Midland, WV2 4HN. ENGLAND

产品名称和系列、型号、规格

剩余电流动作继电器

RESYS M40, RESYS N40; Un: AC690V; In: 1000A; RESYS

M40: Usn: DC12-125V, AC115/230V, AC400V; RESYS N40: Usn: AC/DC24-230V; 输出触头: RESYS M40: 继电器 1: AC-15: Ue/Ie: AC250V/2.5A; 继电器 2: AC-15: Ue/Ie: AC250V/4A; RESYS N40: 继电器 1, 继电器 2: AC-15: Ue/Ie: AC250V/2.5A; RESYS

M40: I $\Delta$ n: 30mA, 100mA, 300mA, 500mA, 1A, 3A, 5A, 10A, 30A (可调); RESYS

N40: I $\Delta$ n: 30mA, 100mA, 300mA, 500mA, 1A, 3A, 5A, 10A, 20A, 30A (可调); 额定剩余动作类型 A 型, AC 型; I $\Delta$ w: 10kA

产品标准和技术要求

GB/T 22387-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》(CNCA-C03-02:2024)的要求,特发此证。

发证日期: 2024年06月28日 有效期至: 2029年06月27日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,也可在认监委网站([www.cnca.gov.cn](http://www.cnca.gov.cn))查询。



签发:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司







# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，不得单独使用  
This translated document does not have legal validity and cannot be used in isolation

CERTIFICATE NO.: 2024010306649413

NAME AND ADDRESS OF THE APPLICANT  
SOCOMEC S.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND ADDRESS OF THE MANUFACTURER  
SOCOMEC S.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND LOCATION OF THE FACTORY  
BROYCE CONTROL LTD  
Pool Street Wolverhampton, West Midlands, WV2 4HN. ENGLAND

PRODUCT NAME, MODEL AND SPECIFICATION  
EARTH LEAKAGE PROTECTION RELAYS

RESYS M 40, RESYS N 40; Un: AC 690V; In: 1000A; RESYS M 40; Un: DC 12-125V, AC 115/230V, AC 400V; RESYS N 40; Un: AC DC 24-230V; Output contact: RESYS M 40; Relay 1: AC-15; Ue/Te: AC 250V /2.5A; Relay 2: AC-15; Ue/Te: AC 250V /4A; RESYS N 40; Relay 1, Relay 2: AC-15; Ue/Te: AC 250V /2.5A; RESYS M 40; Idn: 30mA, 100mA, 300mA, 500mA, 1A, 3A, 5A, 10A, 30A (Adjustable); RESYS N 40; Idn: 30mA, 100mA, 300mA, 500mA, 1A, 3A, 5A, 10A, 20A, 30A (Adjustable); Rated Residual Operating Type: A, AC; Icw=Idw: 10kA

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS  
GB/T 22387-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C03-02:2024).

Valid from: Jun.28,2024 Valid until: Jun.27,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

