



Certificate of Compliance

Certificate: 2316514 **Master Contract:** 189705
Project: 80240573 **Date Issued:** 2025-02-17
Issued to: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, Bas-Rhin 67235
France

The products listed below are eligible to bear the CSA Mark shown



Issued by: Steven Montminy
Steven Montminy

PRODUCTS

Class 4651 02 SWITCHES - Dead-front (Open Type)

PART A - Open Type Switches, Manual

Model(s)	Cat No	Rated Power (HP)	Rated Power (HP)	Rated Power (HP)	Current (A)	Short Circuit Current Rating (SCCR) (kA)	Wire Range (AWG)
22013003, 22013006, 22003010, 22BU3010	22013003 or 22011003	25HP max at 600Vac, 3 ph	10HP max at 480Vac, 1ph	5HP max at 250Vdc	General use: 30A at 600Vac, 30A at 250Vdc	100kA at 600Vac.	10 to 2/0 AWG
	22013006 or 22011006	50HP max at 600Vac, 3 ph	25HP max at 480Vac, 1ph	10HP max at 250Vdc	General use: 60A at 600Vac, 60A at 250Vdc	100kA at 600Vac.	6 to 2/0 AWG
	22003010 or 22001010	50HP max at 600Vac, 3 ph	25HP max at 480Vac, 1ph	15HP max at 250Vdc	General use: 100A at 600Vac, 100A at 250Vdc	100kA at 480Vac, 25kA at 600Vac.	3 to 2/0 AWG

Note:



Certificate: 2316514

Master Contract: 189705

Project: 80240573

Date Issued: 2025-02-17

- Can be added with a fourth pole rated 30A, Cat. No. 22011003 or
- Can be added with a fourth pole rated 60A, Cat No. 22011006 or
- Can be added with a fourth pole rated 100A, Cat No. 22001010.
- Cat. No. 22BU3010 is Cat. No. 22003010 with the handle Cat. No. 22995032 already mounted on the switch.

Solid Neutral pole with Cat Nos 22005011 and Solid earthing pole with Cat Nos 22009011.

PART B - Terminal shroud

Model(s)
22943016, 22941011, 2B943016

PART C - Component handle

Model(s)
22995032

Notes:

1. These devices are manual open type switches intended for general use and having ampere ratings with horsepower ratings.
2. For use in enclosures minimum size: 12 by 8 by 6 inches for catalogue number 22013003, 22011003 , 22013006, 22011006 and enclosure minimum size: 14 by 8 by 6 inches for catalogue number 22003010, 22001010.
3. The terminal shroud Cat. Nos. 22943016 and 2B943016 are for use with 3 pole switches, Cat. Nos. 22013003, 22013006, 22003010.
4. The terminal shroud Cat Nos 22941011 is for use with the four pole switches Cat. Nos. 22011003, 22011006, 22001010.
5. The handle is for use with 3 pole switches, Cat. Nos. 22013003, 22013006, 22003010 or equipped with a four pole switches Cat. Nos. 22011003, 22011006, 22001010.
6. These devices are certified as components for use in equipment where the suitability of the combination is determined by CSA.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 4:16 - Eighth Edition - Including Update No. 2 - January 2023 - Enclosed and dead-front switches